



1000KVA
3 PHASE

50 Hz

GENERATING SET MODEL (UPS P 1000)

	Prime	Standby
380-415 V, 3 ph, 50 Hz, 1500 rpm	910 KVA	1000 KVA
	728 KW	800 KW
380-415 V, 3 ph, 60 Hz, 1800 rpm	KVA	KVA
	KW	KW

ENGINE / TECHNICAL DATA

Ratings at 0.8 Power Factor

Engine Make	Cummins	
Engine Model	KTA38-G2A	
Governing Type	Electronic	
Number of Cylinders	12	
Cylinder Arrangement	60°V	
Bore and Stroke mm	159X159	
Displacement / Cubic Capacity litres	38.0	
Induction System	Turbocharged and air to air charge cooled	
Cycle	4 stroke	
Combustion System	Direct Injection	
Compression Ratio	14.5:1	
Rotation	Anti-clockwise, viewed from flywheel end	
Cooling System	Water - cooled	
Frequency and Engine Speed	50Hz & 1500rpm	60Hz & 1800rpm
Gross Engine Power kW (hp)	882 (1183)	969 (1299)
Fuel Consumption @ 50% load L/hr	109.6	
@ 75% load L/hr	154.2	
@ 100% load L/hr	198.8	
Total Lubrication System Capacity litres	135.1	135.1
Total Coolant Capacity litres	123.8	123.8
Exhaust Temperature: °C	521	531
Fuel Tank Capacity: litres		

Image for illustrative purposes only



1000KVA
3 PHASE

60 Hz

ALTERNATOR DATA

Make	UPS / Leroy Somer
Model	UPS404J / TAL049 E
No. of bearings	1
Insulation class	H
Wires	6/12
Ingress Protection	IP23

Winding Pitch	2/3
AVR Model	
Overspeed	2250 mn ⁻¹
Voltage Regulation (steady)	± 0.5%


CONTROL PANEL

Make	Deep Sea
Model	7000 SERIES

The **DSE 7000 Series** is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- Fuel level (Warning or shutdown) - Optional
- Hours run counter
- Battery volts
- Fail to start/stop
- Emergency stop
- Failed to reach loading voltage/frequency
- Charge fail
- Loss of magnetic pick-up signal - Optional
- Low DC voltage
- CAN diagnostics and CAN fail/error
- Low DC voltage



1000 KVA**3 PHASE****50 Hz****STANDARD SPECIFICATIONS****1000KVA****3 PHASE****60 Hz****1. ENGINE**

Cummins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filter.
 - Two Cartridge type fuel filters.
 - Full flow lube oil filter.
- All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

4. EXHAUST SYSTEM

Exhaust Gas flow	201 m3/min
Maximum allowable back pressure	3.0 (kPa)

5. CIRCUIT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. ALTERNATOR**6.1 INSULATION SYSTEM**

- The insulation system is Class H.
- All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin.
- Heavy coat of antitracking varnish additional protection against moisture or condensation.

6.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 1\%$. Nominal adjustment by means of a trim pot incorporated on the AVR.

7. MOUNTING ARRANGEMENT**7.1 COUPLING**

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

7.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

7.3 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

8. FACTORY TEST

- The Generating set is load tested before dispatch
- All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

9. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

10. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

11. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.

12. WARRANTY


All of the Generating Sets are covered under a warranty policy for a period of 12 months or 1000 working hours. Warranty of the equipment is in line with manufacturers warranty terms & conditions.

(check warranty statement for more details, as it may vary for different countries)

In line with continuous product development, we reserve the right to change specifications without notice.

STANDARD GENERATOR DIMENSION AND WEIGHT

Containerized Type with Silent Soundproof Canopy



Open Type (without Soundproof Canopy)

