

Mikas Middle East FZE

Ratings at 0.8 Power Factor

Office No: 139/A, Building -Q1-04 **Sharjah Airport International Freezone** PO Box: 61397, Sharjah **United Arab Emirates.**

Machinery for Industrial Kinetics, Access, and Services

mikas.ae

100 KVA

3 PHASE

50 Hz

Perkins

GENERATING SET MODEL(UPS P 100)			
Output Ratings	Prime	Standby	
380-415 V, 3 ph, 50 Hz, 1500 rpm	100 KVA	110 KVA	
	80 KW	88 KW	
380-415 V, 3 ph, 60 Hz, 1800 rpm	114.4 KVA	126.5 KVA	
	90 KW	100 KW	

ENGINE / TECHNICAL DATA

Engine Make Perkins 104C-44TAG2 **Engine Model Governing Type** Electronic **Number of Cylinders Cylinder Arrangement** Vertical in line 105 x 127 Bore and Stroke mm **Displacement / Cubic Capacity litres** 4.41 **Induction System** Turbocharged, air to air Cycle 4 stroke **Direct Injection Combustion System Compression Ratio** 18.2:1 Anti-clockwise, viewed on flywheel Rotation Water - cooled **Cooling System** Frequency and Engine Speed 50Hz & 1500rpm / 60Hz & 1800rpm Prime Standby Fuel Consumption @ 50% load L/hr @ 75% load L/hr 22.6 @ 100% load L/hr 24.9 **Total Lubrication System Capacity litres** 8 8 Total Coolant Capacity (inc. radiator) litres 12.6 12.6 Exhaust Temperature: °C 514 543

114.4 KVA 3 PHASE

ALTERNATOR DATA		
Make	UPS / LEROY SOMER	
Model	UPS274C / LSA(TAL)044D	
No. of bearings	1	
Insulation class	Н	
Wires	6/12	
Ingress Protecti	on IP23	
Excitation Syste	m SHUNT	
Winding Pitch	2/3	

Overspeed	2250 mn ⁻¹
Voltage Regulation (steady)	± 1%

CONTROL PANEL Deep Sea Make 4000 SERIES Model

The DSE4000 Series is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm indications:

- Generator frequency
- · Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- · Hours run counter
- Battery volts
- Fail to start/stop
- **Emergency stop**
- Failed to reach loading voltage/frequency
- Charge fail
- · Low DC voltage
- CAN diagnostics and CAN fail/error

Image for illustrative purposes only









100 KVA

STANDARD SPECIFICATIONS

114.4 KVA

50 Hz

1. ENGINE

ccess, and Services

Perkins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

Cartridge type dry air filter.

7. ALTERNATOR

7.1 INSULATION SYSTEM The insulation system is Class H.

All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a

special polyester resin.

9. FACTORY TEST

The Generating set is load tested before dispatch All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring Commissioning / Fault Finding instruction accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.

13. WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months or 1000 working hours, Warranty of the equipment is in line with manufacturers warranty terms & conditions.

In line with continuous product development, we reserve the right to change specifications without notice.

mikas.ae

Perkins

5. CIRCUT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

8.2 ANTI-VIBRATION MOUNTING PADS


Anti-Vibration pads are affixed between the Engine Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.


8.3 SAFETY GUARDS


The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.


STANDARD GENERATOR DIMENSION AND WEIGHT

Silent Type (with Soundproof Canopy)









Open Type (without Soundproof Canopy)

